OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER P.W.D BUILDING SUB-DIVISION, HAILAKANDI ASSAM SON ALLOWN

BUILDING SAFETY CERTIFICATE

No. 1712

Date: 29.103.1202-1

Certified that existing building GLOBAL PUBLIC CENTRAL SCHOOL at Lakshmisahar-XVI, Hailakandi, Assam, Pin-788152 comprised of Ground Floor, basement(s) and First Floor owned/occupied by GLOBAL PUBLIC CENTRAL SCHOOL have complied with the building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of Hailakandi Public Works Department on 261e3/2024 in the presence of The Principal, Mr. Dilwar Aman Manna and that the building/premises is fit for occupancy upto classes NURSERY to 12th with effect from 01/03/2024 for a period of ONE years in accordance with rule and subject to compliance of the specific conditions as appended.

- 1. Ramp and railing provided for physically handicapped Students.
- 2. Stair case width is 1.50 mts, Rise of steps is 0.15 mts, tread is 0.30mts
- 3. Ceiling height from floor measured and it is is 3.45 mts.
- 4. Paved roads, available for the movement of fire engine around building

Issued on Q6/03/2029 atby

Strike out whichever is not applicable

Signature with Seal.

Asstt. Engineer, PWD

Building Division, Hallakani Designation Assai kur Engineen

Name & Address of Department/Office. a L. the. A. E. E. PWD(1)

(Assistant Engineer & Above officer concerned Govt. Department only)

Note:- This certificate should be signed/Issued by Assistant Engineer & above officer of concerned Govt. Department only.

*The filling up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as single pdf.

Principal School Public Central School Global Public Central School Global