

GOVT. OF ASSAM  
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER (PHE)  
HAILAKANDI SUB-DIVISION  
HAILAKANDI



PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. PHE/DLL/HKD/Y24-01

Dated: 15.02.24

It is certified that an inspection team headed by Manas Jyoti Das, AE (PHE) (Name of Officers with designation) from Hailakandi PHED inspected the **GLOBAL PUBLIC CENTRAL SCHOOL, LAKSHMISAHAR-XVI, HAILAKANDI** (Name & Address of the school) on 15.02.24 (date of inspection) and on the basis of Water Test report (Attached) bearing no. D.N./PS/Y24-37 dated 15.02.24 of (PHED Lab) certified that the **GLOBAL PUBLIC CENTRAL SCHOOL, LAKSHMISAHAR-XVI, HAILAKANDI** (Name of School) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T Govt.

Nodal Officer

(AE (PHE), Hailakandi)

Signature with Seal: .....

Name

MANAS JYOTI DAS

Designation

Asstt. Engineer (PHE) cum Nodal officer  
DLL, Hailakandi

Name & Address of the Office/ Department: .....

o/o Executive Engineer (PHE) Hailakandi  
Division, Circuit House Road, Hailakandi

To,  
Global Public Central School  
Lakshmisahar, Ward No-XVI  
Hailakandi

Self Attested.

Principal  
Global Public Central School  
Lakshmisahar, Hailakandi



**District Level Laboratory**  
**Public Health Engineering Department**  
[Government of Assam]  
Hailakandi 788155



Email ID: dillphchkd@gmail.com

Ph. No: 9859528946

**Test Report**

Issue Date: 16.02.2024

Test Report No. : PHE/DLL /HKD/DW/PS/Y24-37  
Issued To:  
Customer Name : Global Public Central School, Hailakandi (Assam)  
Sample Description : Ground Water  
Sample Type : Drinking Water (Treated)  
Sample collected on dated : 15.02.2024  
Sample Collected by : Badrul Islam Laskar  
Sample received on dated : 15.02.2024  
Sample Location : Hailakandi Town W/No.- 16 (Lakshmisahar), Dist.: Hailakandi (Assam)  
Sample Quantity : 1000 ml  
Date of Analysis started : 15.02.2024  
Dated of analysis completed : 15.02.2024

Sr. No.	Parameter	Protocol Used	Results	IS:10500:2012 (Second Revision)		Unit
				Desirable limit	Max. Permissible limit (in absence better alternate source)	
1	Colour	IS: 3025 (Part 4)	Agreeable	Agreeable	Agreeable	NTU
2	Taste	IS: 3025 (part 8)	2	1	5	pH unit
3	Turbidity	IS: 3025 (Part 10)	6.89	6.5 – 8.5	No relaxation	mg/L
4	pH	IS: 3025 (Part 11)	188	500	2000	mg/L
5	TDS	IS: 3025 (Part 16)	-	250	1000	mg/L
6	Chloride	IS : 3025 (Part 32)	52	200	600	mg/L
7	Total Alkalinity (as CaCO <sub>3</sub> )	IS: 3025 (Part 23)	96	200	600	mg/L
8	Total Hardness (as CaCO <sub>3</sub> )	IS: 3025 (Part 21)	-	75	200	mg/L
9	Calcium (as Ca)	IS: 3025 (Part 40)	-	30	100	mg/L
10	Magnesium (as Mg)	APHA (24th Ed) 3500 Mg B	0.27	1	No relaxation	mg/L
11	Total Iron (as Fe)	APHA 3500 (24th Ed) Fe B	< 0.1	1	1.5	mg/L
12	Fluoride (as F)	APHA (24th Ed) 4500-F Method C	10	45	No relaxation	mg/L
13	Nitrate (as NO <sub>3</sub> )	APHA (24th Ed) 4500 NO <sub>3</sub> D	24.9	200	400	mg/L
14	Sulphate (as SO <sub>3</sub> )	IS 3025 (Part 24)				

**Notes:**

- The results given above are related to the sample as received and tested in this laboratory. Reliability of sample lies with the sender.
- The test report cannot be regenerated/re-produced in whole or in part without written permission of Laboratory.
- The test report cannot be used for any publicity or any legal purpose.
- The test samples meant for chemical analysis will be disposed of after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.

\*\*\* BDL= Below Detectable Limit (For Arsenic BDL= < 0.005 ppm)

Sample analyzed by: Subrata Choudhury

(Name)

Authorized Signatory/Chemist

Lab Name: DLL, HKD

**END OF TEST REPORT**

Principal  
Global Public Central School  
Lakshmisahar, Hailakandi

